

Northern Electricity Supply Company Ltd. (NESCO)

Bidyut Bhaban, Hetemkhan, Rajshahi, Bangladesh

Memo no.: 27.29.0000.014.07.070.20-268 Date: 16/09/2020

Clarification-1

Tender No.: Lot-2 of Package-4

Project Name: Extension & Renovation Project Of Distribution Line & Sub-Station Of Rajshahi Division

Tender Name: Planning, Design, Supply, Construction, Supervision, Erection , Testing & Commissioning of 33 KV GIS Switching station at Miapur 230/132/33 KV Grid, Rajshahi on turnkey basis (NCT).

Sl. No.	Reference Section/Clause	Tenderer's Queries	NESCO's Response
1		Is it a local or international tender? What would be the currencies? Can USD be quoted as it is mentioned in price schedule? Please Clarify	Absolutely Local Tender. Price Schedule should be quoted only in BDT. Format of Standard Tender Document (PG5A) by CPTU has been used.
2	GTP (Page 342-344) and (Page 147)	Auxiliary Transformer: Is it Dry Type or Oil Type? In GTP (Page 342-344) it is mentioned as Oil Type but in Price Schedule (Page 147) it is mentioned as Dry Type. Please Clarify.	<i>See Amendment-1 Sl. No. 1</i>
3	Page 189	Training and Supervision on Products at Origin of Products: In page 189, it is mentioned in the beginning that training and supervision shall be held for GIS but in the following description Relay, SAS are included with GIS. Please clarify on which products such training will be conducted? Also please mention how many people will participate for each item for how many days? Should it be one team, two teams or three teams? Should there be any overseas training under the Covid situation? Please clarify.	<i>See Amendment-1 Sl. No. 2</i>
4	In GCC 38.2, page 106	Witnessing of the manufacturing process and tests of the Goods at Manufacturer's Works: In GCC 38.2, page 106; Inspection are mentioned for three teams having 3 members in each team. But there are four items (GIS Breaker, Protection Relay, LA/Surge Arrester and Power Cable) to inspect. Please clarify how many products inspections will be conducted?	As per tender document
5	page P188	In page P188; Local Training: For 15 people how many days of Training shall be conducted? What about Accommodation, Transportation and Per Diem; who will bear? Please clarify.	<i>See Amendment - 1 Sl. No. 3</i>
6	Section-5 (Tender and Contract Forms) Price Schedule No. 2 (Page 147-1.02)	As per price schedule provided by you, in item no. 1.02, 1 no. Bus Sectionalizer is mentioned. Bus Coupler is not mentioned in the line items. Kindly note that, the total panels will be 4 nos. for Bus Coupler and Bus Sectionalizer. 2 nos. Bus Coupler	As per tender document

Sl. No.	Reference Section/Clause	Tenderer's Queries	NESCO's Response
		and 2 nos. Bus sectionalizer.	
7	Section-5 (Tender and Contract Forms) Price Schedule No. 2 (Page 147-1.02)	In item no. 1.04, Bus PTs should be 4 sets instead of the mentioned 2 sets.	<i>See Amendment – 1 Sl. No. 4</i>
8	Section-5 (Tender and Contract Forms) Price Schedule No. 5 (Page 149-1.05)	In item no. 1.05, Auxiliary Transformer feeder mentioned as 1 no. Previously it was 3 nos. and till now price schedule-5 the auxiliary transformer quantity is 3 NOS Kindly confirm the exact quantity	<i>See Amendment – 1 Sl. No. 5</i>
9	(Page 339-Sl no-47)	In GTP, item no. 47, Current Transformer ratio changed to 2400-1200/1-1-1A instead of earlier 3000-1500/1-1A. Kindly confirm the correct requirement. As the panels are with 3000A CB and DS, why not stay with 3000-1500/1-1A, which will allow maximum Current flow? Please check and confirm.	As per tender document


